



Optimization of temperature levels in decentralized solar feed-in heat grids

A case study of Dutch refurbished building in a residential neighbourhood

Saleh Mohammadi, Sabine Jansen, Sam van der Zwan, Cees Mager





Decentralized Low Temperature Feed-in Heat Grids with PVT

DeZONNET Consortium

DeZONNET is a TKI* Urban Energy project funded by the Netherlands Enterprise Agency (RVO)



*Topconsortia voor Kennis en Innovatie



Innovation Fund Denmark



Background information

(Neighborhood and Case study building)



Natural gas-free neighborhoods (Aardgasvrije wijken)



120 miljoen euro voor 'proeftuinen' aardgasvrije wijken
in 27 gemeenten

SPAARGAS
DOE MEE!



Natural gas-free neighborhoods (Aardgasvrije



27 aardgasvrije wijken

120 miljo
in 27 ger



- | | | |
|----|-------------------|----------------------------------|
| 1 | Amsterdam | Van Der Pekbuurt |
| 2 | Appingedam | Opwierde-Zuid |
| 3 | Assen | Lariks West |
| 4 | Brunssum | Brunssum-noord |
| 5 | Delfzijl | Delfzijl Noord |
| 6 | Den Haag | Bouwlust/Vrederust |
| 7 | Drimmelen | Terheijden |
| 8 | Eindhoven | t Ven |
| 9 | Groningen | Paddepoel en Selwerd |
| 10 | Hengelo | Nijverheid |
| 11 | Katwijk | Smartpolder |
| 12 | Loppersum | Loppersum-'t Zandt- Westeremden |
| 13 | Middelburg | Dauwendaele |
| 14 | Nijmegen | Dukenburg |
| 15 | Noordoostpolder | Nagele |
| 16 | Oldambt | Nieuwolda-Wagenborgen |
| 17 | Pekela | Boven Pekela en de Doorsneebuurt |
| 18 | Purmerend | Overwhere-Zuid |
| 19 | Rotterdam | Pendrecht |
| 20 | Sittard-Geleen | Limbrichterveld-Noord |
| 21 | Slidrecht | Slidrecht-Oost |
| 22 | Tilburg | Quirijnstok |
| 23 | Tytsjerksteradiel | Garyp |
| 24 | Utrecht | Overvecht Noord |
| 25 | Vlieland | Duinwijk |
| 26 | Wageningen | Benedenbuurt |
| 27 | Zoetermeer | Palenstein |



SPAAR_{gas}
DOE MEE!


Duurzaam Ramplaankwartier

Natural gas free neighborhood & local generation as much as possible



DE RAMPLAAN
duurzame energie in onze wijk


DeZONNET Concept



Many small decentralized solar feeding points with PVT


3 possible situations occur:

- Direct use of solar heat by the heat pump in the house
- Supply heat to the network (or: take cold from the network)
- Direct use of heat from the network



Collective LT-ATES grid

Low temperature network with the supply around 20°C (this depends on the season, but in any case it has higher temperature than standard ATES net. Return pipe approx. 10-12°C)



One or more ATES systems connected to the LT grid

ATES

SPAAR_{gas}
DOE MEE!



Duurzaam Ramplaankwartier

Natural gas free neighborhood & local generation as much as possible



DE RAMPLAAN
duurzame energie in onze wijk

SPAAR_{gas}
DOE MEE!



Selected building case study

A dwelling located in Pieter Wantelaan 4, 2015EB Haarlem municipality is selected. The building was designed by Brahen & Buma and built in 1958.



Renovation scenarios

Status quo



Ground floor

$$U = 2.53 \text{ W/m}^2\text{k}$$

Roof

$$U = 1.48 \text{ W/m}^2\text{k}$$

Wall

$$U = 1.38 \text{ W/m}^2\text{k}$$

Windows

$$U = 4.80 \text{ W/m}^2\text{k}$$

C Renovation (C label)



Ground floor

$$U = 1.41 \text{ W/m}^2\text{k}$$

Roof

$$U = 0.44 \text{ W/m}^2\text{k}$$

Wall

$$U = 0.56 \text{ W/m}^2\text{k}$$

Windows

$$U = 2.00 \text{ W/m}^2\text{k}$$

B Retrofitting (B label)



Ground floor

$$U = 0.36 \text{ W/m}^2\text{k}$$

Roof

$$U = 0.36 \text{ W/m}^2\text{k}$$


Wall

$$U = 0.36 \text{ W/m}^2\text{k}$$

Windows

$$U = 1.72 \text{ W/m}^2\text{k}$$

A Deep Retrofitting



Ground floor

$$U = 0.12 \text{ W/m}^2\text{k}$$

Roof

$$U = 0.10 \text{ W/m}^2\text{k}$$

Wall

$$U = 0.10 \text{ W/m}^2\text{k}$$


Windows

$$U = 0.90 \text{ W/m}^2\text{k}$$


Annual energy demand of the study building for different renovation scenarios

Scenarios	Electricity demand [kWh/y]	Space Heating (SH) [kWh/y]	Domestic Hot Water (DHW) [kWh/y]	SH Equivalent gas volume [Nm ³ /y]	DWH Equivalent gas volume [Nm ³ /y]
Status quo	3,144	14,055	3011	1,701	423
C Renovation	3,144	10,951	3011	1,325	423
B Retrofitting	3,144	6,513	3011	788	423
A Deep Retrofitting	3,144	3,044	3011	368	423
* With the efficiency ratio of 85% **With the efficiency ratio of 73%					

Load duration curve (kW) of the study building (Space heating- Status quo)



Effect of the renovation scenarios on load duration curve and heating power demand




Modelling the Stand-alone Situation


(TRIPLE-SOLAR System Replication and Validation)



Concept – Building Levels




Measured output of the applied PVT for fixed input temperature (Consolar Solink PVT)



T-intrede (°C)	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total (kWh)
10	8	20	55	78	114	145	150	155	100	64	18	7	913

Measured output of the applied PVT for fixed input temperature (Consolar Solink PVT)




Collector field yield for 10 °C input temperature and 90 l/h flow: 919 kWh/m²/Year

OMGEVINGSCOLLECTOR/ WARMTEPOMPSYSTEEM VAN TRIPLE-SOLAR (Gelijkwaardigheidsverklaringen)

Important assumptions:


- **NIBE F1255 6 kW,**
- Maximum temperature of **30°C** on the evaporator side
- Tap water tank with a capacity of **180 liters**
- With the PVT surface of **12 and 16 m²**
- Gross heat demand of **5-10-20-30-40-50 GJ/year**
- For an indoor temperature of **20°C**
- generation efficiency for space heating and hot tap water




	Bruto warmtebehoefte QH;dis;nren [GJ]					
	2,5	5	10	20	40	60
$\eta_{H;opw} [-] @ QH;dis / Ag;tot \leq 150 \text{ MJ/m}^2$	4,16	4,91	5,39	5,63	5,45	5,54
$\eta_{H;opw} [-] @ QH;dis / Ag;tot > 150 \text{ MJ/m}^2$	3,84	4,76	5,39	5,76	5,92	5,73

	Tapwatervraag QW;dis;nren [GJ]			
	6,5	9	11,5	14
$\eta_{W;opw} [-] @ QH;dis / Ag;tot \leq 150 \text{ MJ/m}^2, \text{ en } > 150 \text{ MJ/m}^2$	3,46	3,61	3,68	3,77

Simulated setup for the stand-alone scenarios




Control system implemented for the stand-alone model




Simulated setup for the stand-alone scenarios

SH: 6513 kWh (23 GJ) DHW: 3011 kWh (10 GJ)
6 Consolar Solink PVT Panels
NIBE 6kW Heat Pump
180l portable DHW Buffer
Flow rate: 55 l/h/m ²
Seasonal performance factor: 4.8
Collector field yield: 692 kWh/m²/year
Total electricity consumption of the system: +280 kWh




Simulated setup for the stand-alone scenarios




Modelling the Grid-connected Situation (Feed-in grid scenario)




Concept – Building/Area Levels



Control system implemented for the grid-connected model




Simulated setup for the grid-connected scenarios



3 possible situations on the building level:


Direct use of solar thermal by the heat pump

- If there will be a demand in the building
- If outdoor $T_e > 8, 6 \text{ \& } 4 \text{ }^\circ\text{C}$




Direct use of heat from the grid

- If there will be a demand in the building
- If outdoor $T_e \leq 8, 6 \text{ \& } 4 \text{ }^\circ\text{C}$




Supply heat to the grid

- only valid for summer months
- If there is no demand in the building
- If PVT mean temperature ($T_{m(PVT)} \geq 20^\circ\text{C}$)




Grid-connected models for the B Retrofitting scenario (6 PVT and $T_e > 8^\circ\text{C}$)

SH: 6513 kWh (23 GJ) DHW: 3011 kWh (10 GJ)
6 Consolar Solink PVT Panels
NIBE 6kW Heat Pump
180l portable DHW Buffer
Flow rate: 55 l/h/m ²
Seasonal performance factor: 7.1
Collector field yield: 572 kWh/m²/year
Total district heating consumption: 4774 kWh
Energy to the grid: 3378 kWh
Total electricity consumption of the system: -93 kWh
Unbalanced capacity: -1395 kWh




Grid-connected models for the B Retrofitting scenario (6 PVT and $T_e > 6^\circ\text{C}$)

SH: 6513 kWh (23 GJ) DHW: 3011 kWh (10 GJ)
6 Consolar Solink PVT Panels
NIBE 6kW Heat Pump
180l portable DHW Buffer
Flow rate: 55 l/h/m ²
Seasonal performance factor: 6.9
Collector field yield: 655 kWh/m²/year
Total district heating consumption: 3625 kWh
Energy to the grid: 3378 kWh
Total electricity consumption of the system: -63 kWh
Unbalanced capacity: -247.2 kWh




Grid-connected models for the B Retrofitting scenario (6 PVT and $T_e > 4^\circ\text{C}$)

SH: 6513 kWh (23 GJ) DHW: 3011 kWh (10 GJ)
6 Consolar Solink PVT Panels
NIBE 6kW Heat Pump
180l portable DHW Buffer
Flow rate: 55 l/h/m ²
Seasonal performance factor: 6.7
Collector field yield: 738 kWh/m²/Year
Total district heating consumption: 2460 kWh
Energy to the grid: 3378 kWh
Total electricity consumption of the system: -24 kWh
Unbalanced capacity: 917.4 kWh




Grid-connected models for the B Retrofitting scenario (4 PVT and $T_e > 8^\circ\text{C}$)

SH: 6513 kWh (23 GJ) DHW: 3011 kWh (10 GJ)
4 Consolar Solink PVT Panels
NIBE 6kW Heat Pump
180l portable DHW Buffer
Flow rate: 55 l/h/m ²
Seasonal performance factor: 6.4
Collector field yield: 738 kWh/m²/Year
Total district heating consumption: 4778 kWh
Energy to the grid: 2470 kWh
Total electricity consumption of the system: 631 kWh
Unbalanced capacity: -2307 kWh




Grid-connected models for the B Retrofitting scenario (4 PVT and $T_e > 6^\circ\text{C}$)

SH: 6513 kWh (23 GJ)
DHW: 3011 kWh (10 GJ)
6 Consolar Solink PVT Panels
NIBE 6kW Heat Pump
180l potable DHW Buffer
Flow rate: 55 l/h/m ²
Seasonal performance factor: 6.3
Collector field yield: 866 kWh/m²/Year
Total district heating consumption: 3634 kWh
Energy to the grid: 2470 kWh
Total electricity consumption of the system: 678 kWh
Unbalanced capacity: -1165 kWh




Grid-connected models for the B Retrofitting scenario (4 PVT and $T_e > 4^\circ\text{C}$)


SH: 6513 kWh (23 GJ)
DHW: 3011 kWh (10 GJ)
6 Consolar Solink PVT Panels
NIBE 6kW Heat Pump
180l potable DHW Buffer
Flow rate: 55 l/h/m ²
Seasonal performance factor: 6
Collector field yield: 992 kWh/m²/Year
Total district heating consumption: 2460 kWh
Energy to the grid: 2470 kWh
Total electricity consumption of the system: 731 kWh
Unbalanced capacity: 10 kWh



Comparing the scenarios for the B Retrofitting scenario



PVT Potential Map (kWh)



AALBORG UNIVERSITY
DENMARK



DISTRICT ENERGY
IN CITIES
INITIATIVE



Innovation Fund Denmark



Fonden Energi- & Miljødata
www.emdfonden.dk



Conclusions

- Decentralized solar feed-in not only led to a higher temperature in the grid, which makes the HPs efficient, but also the PVT ensures the regeneration of the ATES over the year
- Decreasing the outside temperature threshold increase the self-sufficiency of the system on the building level, however decrease the COP of HPs
- Number of PVTs is one of the important constraints of the systems that has to be optimized to balance the shortage and surplus of the ATES system
- The model helps to identify the influential factors on the performance of the feed-in grid system