



## **OPERATION OF DISTRICT COOLING SYSTEM IN COLD CLIMATES WITH EXISTING DISTRICT HEATING**

**Igor Krupenski**

A.Volkova, A.Ledvanov, V.Mašatin, E.Latõšov, H.Pieper, L. Murauskaitė  
Tallinn University of Technology, HeatConsult OÜ, Utilitas Tallinn AS

06.10.2020



# DISTRICT COOLING IN ESTONIA



Tartu





Pärnu




Tallinn

# 3 DC REGIONS IN TALLINN





# MASTERPLANS FOR ALL REGIONS










# ÜLEMISTE CITY

Smart City – District Heating and District Cooling




# CAPACITIES (EXISTING + NEW BUILDINGS)






# DESIGN PROJECT FOR HEATING AND COOLING





# HYDRAULIC CALCULATIONS FOR NETWORK PERFORMED



P700555  
Diameter: 444,4 [mm]  
Pressure gradient, supply: 39 [Pa/m]  
Velocity, supply: 1,418 [m/s]  
Flow, supply: 219,934 [kg/s]  
Heat loss factor, supply: 0,52 [W/m/C]  
Pressure loss, supply: 1,15 [kPa]

Cooling energy production:

Plant **nr 1** (total: **15** MW):

1. Heat Pump: 3,9 MW
2. Absorbtion Units: 11,1 MW

Plant **nr 2** (total: **75** MW):

1. Chillers: 10 MW
2. Absorbtion Units: 65 MW


Future: interconnection with free cooling network

**NB!** For absorbtion devices heating energy is used which otherwise will be wasted (there are 3 CHP-s in Tallinn which use RES – biomass). CHP-s get subsidies for RES electricity production



## DIFFERENT SUPPLY SOURCES

- Absorption devices from existing HTDH network;
- Free cooling from Baltic Sea, Pae Lake, Ülemiste Lake;
- Heat Pumps
- Compressor Cooling



# MAJOR IMPACTS RELATED OF DC FOR ÜLEMISTE CITY

## Heat losses in DH network will increase:


- Existing temperature in Tallinn DH network during the summer time: 70 °C
- Due to implementation of absorption devices the temperature should be increased up to 90 °C. Additional heating losses due to increased temperature: **4000 MWh / month** (price for DH production in Tallinn: 30 EUR/MWh)

## Economics:


- DC plant nr 1: **4** mil EUR
- DC network (length 3 km): **1,2** mil EUR
- DC plant nr 2 + interconnection pipeline: **25** mil EUR
- DC price for the clients: energy ca **35** EUR/MWh + power fee + connection fee
- Payback time for the project: ca **10** years

## 2,5 times better primary energy efficiency

- Calculation assumptions: PEF for electricity: **2,0**, SEER for local cooling production devices is 4, so DC PEF is 0,5) and PEF for efficient district cooling is **0,2**.



Investment costs (mil EUR)



- DC plant nr 1 (m EUR)
- DC plant nr 2 + interconnection (m EUR)
- DC network (m EUR)



# TAL TECH

**THANK YOU FOR YOUR ATTENTION!**

**IGOR.KRUPENSKI@TALTECH.EE**

